

Caterpillar Trail Public Water District

404 Ten Mile Creek Rd
East Peoria, IL 61611-9240
Phone: (309) 383-4002
Website: www.cattrailwater.org
Email: cattrailwater@mtco.com



05/14/2026

Addenda to Water Tower Cleaning Bid Package Dated May 2026

RE; D2 antimicrobial.

- 1) On page 3 of your bid packet, lines A, B, and C, D2 is specified as the anti-microbial to be used.
- 2) The District will consider all options regarding the treatment of mold and mildew.
- 3) Bidder to propose and specify mold and mildew inhibitor/solution to be used in bid.

Line (a) shall read;

The presoak of each tower applying a mold and mildew inhibitor to all exterior surfaces of the water towers and ground storage tank with a low pressure pump up sprayer to kill all mold and mildew present,

Line (b) shall read;

Power wash all exterior surfaces of the water towers and ground storage tank in accordance with SSPC-SP 12/NACE No. 5, LPWC (1,500 psi maximum),

Line (c) shall read;

Final rinse using a mold and mildew inhibitor to aid against the regrowth of mold and mildew.

5/14/2026

Greg Long
Operations Manager
Caterpillar Trail PWD